



Pandalam Municipality
Pandalam P.O, Pathanamthitta Dist. 689501

Phone – 04734-252251. e-mail : pandalammunicipality@gmail.com


H1-12233/2023

Date – 06/07/2023

Saniary Certificate

This is to certify that the Health and Hygienic conditions of St. Stephen's Public School at Pandalam Municipality are satisfactory and also provide adequate potable drinking water facilities as per the inspection report of Junior Health Inspector Grade 2.


-Secretary,
Pandalam Municipality.




Principal
St. Stephen's Public School
Kudassanad
Principal
St. Stephen's Public School
Kudassanad, Poozhikkadu P.O.. 689 515
Pathanamthitta (Dist.)



QUALITY CONTROL SUB DISTRICT LAB

KERALA WATER AUTHORITY

PARAKODE, ADOOR

Telephone No. 0469 2600833, Email qcvla@gmail.com

TEST REPORT

Report No: PR-2677 /PRKD/07/2023 (MB)	Date Of Test Report: 03.07.2023
St. Stephens Public School Poozhickad P.O Pandalam	
2. Date of Sampling	30.06.2023
3. Time of Sampling	11:30AM
4. Sampling Done by	H 1
5. Sample Code	2023/QCSDL/PRKD PR-2677
6. Source of Sample	DRINKING WATER
7. Sample Quantity	200ml
8. Test performing dates: From: 01.07.2023 To: 02.07.2023	

Sl.No	Parameters	Acceptable limits as per IS 15185-2016	Test Method	Result CFU/100ml
1	Coliforms	Shall not be detected/ 100 ml	Membrane Filtration Method	ABSENT
2	E-coli	Shall not be detected/ 100 ml	Membrane Filtration Method	ABSENT

Remarks:-

NB - The result stated above related only to the sample(s) submitted for testing. The test certificate shall not be reproduced except in full without the written approval of the laboratory.

Verified By

Name: Remya G FOR
Bacteriologist

** End of Report **

Authorized by
Name: Dhanya T.P
Bacteriologist

For

DEPUTY QUALITY MANAGER
QUALITY CONTROL SUB DISTRICT LABORATORY
KERALA WATER AUTHORITY
PARAKODU, ADOOR



QUALITY CONTROL SUB DISTRICT LAB

KERALA WATER AUTHORITY

PARAKODE, ADOOR

Telephone No. 0469 2600833, Email qctvla@gmail.com

TEST REPORT

Report No: PR-2610 /PRKD/06/2023 (NA)		Date Of Test Report: 26.06.2023
Customer Name & Address		
St. Stephens Public School Poozhickad P.o Kudassanad Pandalam Pathanamthitta (Dist)	1. Date of Receipt	23.06.2023
	2. Date of Sampling	23.06.2023
	3. Time of Sampling	03:00PM
	4. Sampling Done by	HI
	5. Sample Code	2023/QCSDL/PRKD PR-2610
	6. Source of Sample	DRINKING WATER
	7. Sample Quantity	:2 LITRE
	8. Test performing dates: From: 23.06.2023 To: 26.06.2023	

Sl.No	Characteristics	Unit	Desirable limits As per IS 10500:2012	Test Method	Status of Accreditation	Limit of Quantification (LOQ)	Result
1	Sulphate (as SO ₄)	mg/L	200	IS 3025(part24/Sec 1)-2022	non accredited	1mg/L	<1
2	Fluoride (as F)	mg/L	1	APHA 4500 – F D	non accredited	0.1mg/L	0.131
3	Iron (as Fe)	mg/L	1	IS 3025(part53) - 2003	non accredited	0.1mg/L	0.109
4	Nitrate (as NO ₃)	mg/L	45	APHA 4500 – NO3 B	non accredited	2mg/L	2.11
5	Residual Chlorine	mg/L	0.2	IS 3025 (part - 26)	non accredited		0.1

Remarks:-

NB – The result stated above related only to the sample(s) submitted for testing. The test certificate shall not be reproduced except in full without the written approval of the laboratory.

Samples will be retained only for 7 days after completion of analysis.

Verified By

Name: Sreedevi . E

Technical Manager

Authorized by

Name: Shahina . S

Deputy Quality Manager

** End of Report **

DEPUTY QUALITY MANAGER
QUALITY CONTROL SUB DISTRICT LABORATORY
KERALA WATER AUTHORITY
PARAKODU, ADOOR